

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Smt. Ranu Tiwari

(Name of Officers with designation) from Chemist PHED

inspected the Krishna Public School, Shivaji Nagar Nandhiya

(Name & Address of the school) on 15/02/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. W7210612513674263 dated 06/03/2024

of PHED District Lab. (PHED Lab) certified that the

Krishna Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30/03/2025

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To Principal

Krishna Public School
Shivaji Nagar Nandhiya
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Jal Jeevan Mission

Har Ghar Jal



District Laboratory, Sidhi

Madhuri Sidhi (Test Address only)

Test report

Sample ID: U7210612513574263

User Information

Name: Krishna Public School Sidhi Mobile: 8770452779
Email: 50882@cbseshiksha.in Pin Code: 486661
Full Address: Village-Shivaji Nagar Naudhiya, Gram Panchayat- Naudhiya, Block-Sidhi, District- Sidhi, State- Madhya Pradesh

Sample description

Source of Sample: Bore Well Village: Naudhiya
Gram Panchayat: Naudhiya Block: Sidhi
District: Sidhi State: Madhya Pradesh
Address: Shivaji Nagar Naudhiya Remarks:
Latitude: Longitude:

Date & time of sample collection: 28.02.2024 | 01:40:00 PM
Date & time of sample received in lab: 28.02.2024 | 02:20:00 PM
Date & time of sample analysed: 29.02.2024 | 10:45:00 AM
Date & time of report generation: 06.03.2024 | 12:45:00 PM

Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)*	mg/l	75	200	85.000	
2	Chloride (as Cl)*	mg/l	250	1000	100.000	
3	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
4	Fluoride (as F)	mg/l	1	1.5	0.000	
5	Iron (As Fe)	mg/l	1	No Relaxation	0.100	

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
6	Magnesium (As Mg)*	mg/l	30	100	42.950	
7	Manganese (As Mn)	mg/l	0.1	0.3	0.000	
8	Nitrate (as NO ₃)	mg/l	45	No Relaxation	8.000	
9	pH*	NA	6.5-8.5	No Relaxation	7.450	
10	Sulphate (as SO ₄)	mg/l	200	400	16.000	
11	TDS	mg/l	500	2000	672.000	
12	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	375.000	
13	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
14	Total Hardness (As CaCO ₃)*	mg/l	200	600	462.130	
15	Turbidity*	NTU	1	5	3.5000	

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

(Signature)
Technical Manager
 Water Testing Lab
 P.H.E. Sub Division Sidhi
 District Sidhi (M.P.)

(Signature)
 Authorised signatory
 Trayambakesh Dwivedi (Test Lab Incharge)
Public Health Engineering
Sub Dn. Sidhi (M.P.)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2023

Print